



Town of Faro Request for Tender #2017-05
ADDENDUM #2
Faro Fire Hall Vehicle Ventilation System

Purpose of this Request for Tender (RFT):

The Town of Faro, Yukon is seeking responses from proponents to install a new vehicle exhaust ventilation system at the fire hall.

RFP Timeline:

RFP Release	Monday, June 26, 2017
REVISED Closing Time	Friday, July, 28 2017 at 12:00 pm (Noon)

See attached Engineering Addendum M-01 (1 page) clarifying the requirement for balancing dampers.

I/we acknowledge Addendum #2:

Name

Company

Please confirm receipt of this addendum with your Proposal submission.



Northern Climate Engineering Ltd.

6A-151 Industrial Rd.

Whitehorse, YT Y1A 2V3

Phone: (867) 667-6900

nce@northernclimate.com

ADDENDUM M-01

DATE OF ISSUE: July 21, 2017

PROJECT TITLE: Faro Firehall Vehicle Exhaust Extraction System

CLIENT/OWNER: Town of Faro

THE FOLLOWING POINTS OF CLARIFICATION OR CHANGE FORM PART OF THE CONTRACT DOCUMENTS AND RELATE TO THE INDICATED SECTION OF SPECIFICATION OR PAGE OF DRAWINGS, AND SUPERCEDE INFORMATION PRESENTLY CONTAINED IN THE TENDER DOCUMENTS.

THIS ADDENDUM IS BEING DISTRIBUTED TO ALL KNOWN HOLDERS OF CONTRACT DOCUMENTS FOR THIS PROJECT. NO CLAIM FOR "EXTRA" LATER IN THE PROJECT WILL BE CONSIDERED DUE TO FAILURE TO NOTIFY A PLAN HOLDER NOT REGISTERED.

1. Scope of Addendum – TENDER DRAWINGS:

Item No.	Sheet	Drawing Name	Description
1.01	M1	Ventilation Plan	Contractor to allow for supply and installation of four blast gate type balancing dampers. Install dampers on each 6" dia. duct branch located within three feet of the 8" dia. trunk ducts.

2. Scope of Addendum – TENDER SPECIFICATIONS:

Item No.	Section	Name	Description
2.01	23 33 10	Ventilation	Add item 2.9 as per below: Blast gate type balancing damper, full collar construction, cast aluminum. .1 Standard of Acceptance: N.R. Murphy L.T.D

End of Addendum