



**Town of Faro Request for Tender #2017-06**  
**ADDENDUM #3**  
**Faro Recreation Centre Generator Installation**

**Purpose of this Request for Tender (RFT):**

The Town of Faro, Yukon is seeking responses from proponents to install a backup power generator at the Faro Recreation centre.

**RFP Timeline:**

RFP Release	Monday, June 26, 2017
<b>REVISED Closing Time</b>	<b>Wednesday, August 2, 2017 at 12:00 pm (Noon)</b>

**See attached:**

- 1) **PART 2 of Form of Tender form to use for submitting the Alternate Pricing. This form must be included with the completed Form of Tender.**
- 2) **Photo showing existing conditions in the generator room. Photos in the earlier engineering addendum showing a rough-in ceiling, wall, light fixture and heating unit are outdated as the area has been cleared in preparation for the generator installation. The engineer will provide further clarification on this in a forthcoming addendum.**

**Closing date/time extended to Wednesday, August 2, 2017.**

I/we acknowledge Addendum #3:

\_\_\_\_\_  
Name

\_\_\_\_\_  
Company

***Please confirm receipt of this addendum with your Proposal submission.***

**FORM OF TENDER, RFT #2017-06, PART 2: ALTERNATE PRICING**

**PROPONENT INFORMATION**

COMPANY NAME: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

CITY, PROV/TERR, POSTAL CODE \_\_\_\_\_

TELEPHONE \_\_\_\_\_

FAX \_\_\_\_\_

EMAIL ADDRESS \_\_\_\_\_

DATE \_\_\_\_\_

NAME & POSITION OF PERSON SIGNING (the "Signee")

\_\_\_\_\_

SIGNATURE OF SIGNEE

"I have fully read & understand this Request for Tender and I have the authority to bind the Proponent"

\_\_\_\_\_

**THE ALTERNATE PRICES BELOW SHALL INCLUDE INSTALLATION. THESE PRICES ARE IN ADDITION TO THE TOTAL BID PRICE ON THE ORIGINAL FORM OF TENDER. PROVISION OF THESE ALTERNATE PRICES DOES NOT OBLIGATE THE TOWN TO INCLUDE THESE ITEMS IN THE SCOPE OF WORK.**

**ALTERNATE PRICING 1**

Provide alternate pricing for a new, single by-pass, automatic transfer switch rated minimum 400Amps 120/208V 3-phase 15kA interrupting current.

ALTERNATE PRICE 1 (exclusive of GST) \$ \_\_\_\_\_

**ALTERNATE PRICING 2**

Provide alternate pricing for a new CDP with sufficient capacity for all existing breakers, plus two additional breakers rated minimum 3-pole 100Amps. Rated minimum 3-phase 400Amp 208V. See attachment A2 for existing CDP breakers.

ALTERNATE PRICE 2 (exclusive of GST) \$ \_\_\_\_\_

Photo of interior of generator room taken Tuesday, July 25, 2017 showing existing conditions.

